

**Senate File 441 - Introduced**

SENATE FILE 441

BY WEBSTER

**A BILL FOR**

1 An Act relating to the national electrical code.

2 BE IT ENACTED BY THE GENERAL ASSEMBLY OF THE STATE OF IOWA:

1 Section 1. Section 103.1, Code 2023, is amended by adding  
2 the following new subsection:

3 NEW SUBSECTION. 10A. *“National electrical code”* means  
4 the national electrical code, 2020 edition, published by the  
5 national fire protection association, as modified by section  
6 103.1B, and excluding sections 210.8(F) and 230.67 of the  
7 national electrical code.

8 Sec. 2. NEW SECTION. 103.1B **National electrical code —**  
9 **alterations.**

10 1. *Definitions.* The definition of “accessible, readily” in  
11 article 100 of the national electrical code, 2020 edition, is  
12 amended to include access to motors for hot spas and similar  
13 devices to be made readily accessible by means of a door on  
14 hinges or the equivalent.

15 2. *Ground-fault circuit-interrupter protection for*  
16 *personnel.* Section 210.8 of the national electrical code, 2020  
17 edition, is amended to include that locations not needed are  
18 dedicated for appliances and approved by the local authority  
19 having jurisdiction as long as it is a single yoke outlet.

20 3. *Dwelling units.* The first sentence of the first  
21 paragraph of section 210.8(A) of the national electrical  
22 code, 2020 edition, is amended to provide that all one  
23 hundred twenty-five volt, single-phase, fifteen-ampere and  
24 twenty-ampere receptacles installed in the locations specified  
25 in sections 210.8(A)(1) through 210.8(A)(11) of the national  
26 electrical code, 2020 edition, and supplied by single-phase  
27 branch circuits rated one hundred fifty volts or less to  
28 ground shall have ground-fault circuit-interrupter protection  
29 for personnel. In lieu of basements, section 210.8(A) of  
30 the national electrical code, 2020 edition, shall apply to  
31 unfinished portions or areas of the basement not intended as  
32 habitable rooms.

33 4. *Receptacle outlets in bedroom.* Section 210.12(A) of  
34 the national electrical code, 2020 edition, is deleted, and  
35 the following means of protection for receptacle outlets in

1 bedrooms are adopted:

2     *a.* A listed combination-type arc-fault circuit interrupter,  
3 installed to provide protection of the entire branch circuit.

4     *b.* A listed branch or feeder type arc-fault circuit  
5 interrupter installed at the origin of the branch-circuit in  
6 combination with a listed outlet branch-circuit type arc-fault  
7 circuit interrupter installed at the first outlet box on the  
8 branch circuit. The first outlet box in the branch circuit  
9 shall be marked to indicate that it is the first outlet of the  
10 circuit.

11     *c.* A listed supplemental arc protection circuit breaker  
12 installed at the origin of the branch circuit in combination  
13 with a listed outlet branch-circuit type arc-fault circuit  
14 interrupter installed at the first outlet box on the branch  
15 circuit where all of the following conditions are met:

16         (1) The branch-circuit wiring shall be continuous from the  
17 branch-circuit overcurrent device to the outlet branch-circuit  
18 arc-fault circuit interrupter.

19         (2) The maximum length of the branch-circuit wiring from  
20 the branch-circuit overcurrent device to the first outlet  
21 shall not exceed fifteen and two-tenths meters or fifty feet  
22 for a fourteen American wire gauge conductor or twenty-one and  
23 three-tenths meters or seventy feet for a twelve American wire  
24 gauge conductor.

25         (3) The first outlet box in the branch circuit shall be  
26 marked to indicate that it is the first outlet of the circuit.

27     *d.* A listed outlet branch-circuit type arc-fault circuit  
28 interrupter installed at the first outlet on the branch  
29 circuit in combination with a listed branch-circuit overcurrent  
30 protective device where all of the following conditions are  
31 met:

32         (1) The branch-circuit wiring shall be continuous from the  
33 branch-circuit overcurrent device to the outlet branch-circuit  
34 arc-fault circuit interrupter.

35         (2) The maximum length of the branch-circuit wiring from

1 the branch-circuit overcurrent device to the first outlet  
2 shall not exceed fifteen and two-tenths meters or fifty feet  
3 for a fourteen American wire gauge conductor or twenty-one and  
4 three-tenths meters or seventy feet for a twelve American wire  
5 gauge conductor.

6 (3) The first outlet box in the branch circuit shall be  
7 marked to indicate that it is the first outlet of the circuit.

8 (4) The combination of the branch-circuit overcurrent  
9 device and outlet branch-circuit arc-fault circuit interrupter  
10 shall be identified as meeting the requirements for a system  
11 combination-type arc-fault circuit interrupter and shall be  
12 listed as such.

13 *e.* If RMC, IMC, EMT, type MC, or steel-armored type AC  
14 cables meeting the requirements of section 250.118 of the  
15 national electrical code, 2020 edition, metal wire-ways, metal  
16 auxiliary gutters, and metal outlet and junction boxes are  
17 installed for the portion of the branch circuit between the  
18 branch-circuit overcurrent device and the first outlet, it  
19 shall be permitted to install a listed outlet branch-circuit  
20 type arc-fault circuit interrupter at the first outlet to  
21 provide protection for the remaining portion of the branch  
22 circuit.

23 *f.* Where a listed metal or nonmetallic conduit or tubing or  
24 type MC cable is encased in not less than fifty millimeters or  
25 two inches of concrete for the portion of the branch circuit  
26 between the branch-circuit overcurrent device and the first  
27 outlet, it shall be permitted to install a listed outlet  
28 branch-circuit type arc-fault circuit interrupter at the first  
29 outlet to provide protection for the remaining portion of the  
30 branch circuit.

31 *g.* Where an individual branch circuit to a fire alarm system  
32 installed in accordance with 760.41(B) or 760.121(B) of the  
33 national electrical code, 2020 edition, is installed in RMC,  
34 IMC, EMT, or steel-sheathed cable, type AC or type MC, meeting  
35 the requirements of 250.118 of the national electrical code,

1 2020 edition, with metal outlet and junction boxes, arc-fault  
2 circuit interrupter protection may be omitted.

3 5. *Guest rooms and guest suites.* In lieu of the  
4 requirements of section 210.12(C) of the national electrical  
5 code, 2020 edition, all one hundred twenty volt, single-phase,  
6 fifteen-ampere and twenty-ampere branch circuits supplying  
7 outlets and devices installed in guest rooms and guest suites  
8 of hotels and motels shall be protected by any of the means  
9 described in subsection 4, paragraphs "a" through "f".

10 6. *Branch circuit extensions or modifications.* In lieu  
11 of the requirements of section 210.12(D) of the national  
12 electrical code, 2020 edition, in any of the areas specified  
13 in section 210.12(B) of the national electrical code, 2020  
14 edition, where branch-circuit wiring is modified, replaced,  
15 or extended, the branch circuit shall be protected by one of  
16 the following, except that arc-fault circuit interruption  
17 protection shall not be required where the extension of the  
18 existing conductors is not more than one and eight-tenths  
19 meters or six feet and does not include any additional outlets  
20 or devices:

21 a. A listed combination-type arc-fault circuit interrupter  
22 located at the origin of the branch circuit.

23 b. A listed outlet branch-circuit type arc-fault circuit  
24 interrupter located at the first receptacle outlet of the  
25 existing branch circuit.

26 7. *Island countertop spacing.* With respect to section  
27 210.52(C)(2) of the national electrical code, 2020 edition, a  
28 length greater than six feet needs two outlets, and then every  
29 four feet, if there is a break in the countertop, two outlets  
30 are needed, one on each side of the break.

31 8. *Dwelling unshared receptacle outlets in bathrooms.* With  
32 respect to section 210.52(D) of the national electrical code,  
33 2020 edition, no outlet, switch, or fixture shall be installed  
34 within three feet of a tub or shower as measured from the tub  
35 surround horizontally, unless protected by a ground-fault

1 circuit interrupter before the device.

2 9. *Residential circuit calculations.* With respect to  
3 article 220 of the national electrical code, 2020 edition, the  
4 following calculations shall apply for residential circuits:

5 a. For lighting outlets, ten per circuit, unless approved by  
6 the authority having jurisdiction.

7 b. For convenience outlets in general duplex receptacles,  
8 ten per circuit.

9 c. For convenience outlets in a kitchen, two per circuit.  
10 Receptacles on the same circuit shall not service the same area  
11 of the countertop.

12 10. *Wiring methods for one thousand volts, nominal, or*  
13 *less.* Sections one, two, seven, and fourteen of section 230.43  
14 of the national electrical code, 2020 edition, are deleted.

15 11. *Service equipment — disconnecting means.* With  
16 respect to section 230.70(A) of the national electrical code,  
17 2020 edition, any nonfused or unprotected service entrance  
18 conductors entering a home or business extending over ten  
19 feet from the point of entrance into the building require a  
20 disconnect to be installed on the building exterior.

21 12. *Feeder taps.* With respect to section 240.21(B) of the  
22 national electrical code, 2020 edition, no taps or splices  
23 shall be allowed on feeders or subfeeders unless approved by  
24 the local authority having jurisdiction.

25 13. *Cables and raceways installed in shallow grooves.* With  
26 respect to section 300.4(F) of the national electrical code,  
27 2020 edition, all connections which use the EMT conduit,  
28 flexible metallic tubing, sealtight metallic conduit, et  
29 cetera, shall utilize insulated throats.

30 14. *Fittings.* With respect to section 300.4(G) of the  
31 national electrical code, 2020 edition, all connections which  
32 use the EMT conduit, flexible metallic tubing, sealtight  
33 metallic conduit, et cetera, shall utilize insulated throats.

34 15. *Conductors.* In lieu of the requirements of section  
35 310.3 of the national electrical code, 2020 edition,

1 conductors, whether solid or stranded, shall be no smaller than  
2 number twelve copper or number ten aluminum or copper-clad  
3 aluminum except for the following:

4     *a.* Flexible cords as permitted by section 400.12 of the  
5 national electrical code, 2020 edition.

6     *b.* Fixture wire as permitted by section 402.6 of the  
7 national electrical code, 2020 edition.

8     *c.* Fractional horsepower motors as permitted by section  
9 430.22(F) of the national electrical code, 2020 edition.

10     *d.* Cranes and hoists as permitted by section 610.14 of the  
11 national electrical code, 2020 edition.

12     *e.* Elevator control and signaling circuits as permitted by  
13 section 620.12 of the national electrical code, 2020 edition.

14     *f.* Class one, two, and three circuits as permitted by  
15 sections 725.27(A) or 725.82(B) of the national electrical  
16 code, 2020 edition.

17     *g.* Fire-protective signaling circuits as permitted by  
18 section 760.27(A) or 760.82(B), or the exception to section  
19 760.51 of the national electrical code, 2020 edition.

20     *h.* For type V cables, minimum conductor sizes are as  
21 follows:

22         (1) Number twelve for one thousand two hundred volt rating.

23         (2) Number ten for three thousand volt rating.

24         (3) Number eight for four thousand volt rating.

25     *i.* Motor control circuits as permitted by section 430.72 of  
26 the national electrical code, 2020 edition.

27     *j.* Control and instrumentation circuits as permitted by  
28 section 727.6 of the national electrical code, 2020 edition.

29     *k.* Electric signs and outline lighting as permitted in  
30 sections 600.31(B) and 600.32(B) of the national electrical  
31 code, 2020 edition.

32     *l.* Smoke detector circuits in all occupancies, which may use  
33 number fourteen wire.

34     16. *Permitted uses for nonmetallic-sheathed cable.* With  
35 respect to the requirements of section 334.10 of the national

1 electrical code, 2020 edition, all feeder and subfeeder wiring  
2 in commercial, industrial, public, and apartment buildings and  
3 single-family and multifamily dwellings shall be installed in  
4 either rigid metal conduit, electrical metallic tubing, or  
5 polyvinyl chloride, or in special cases as determined by the  
6 inspector.

7 17. *Exposed work in unfinished basements and crawl*  
8 *spaces.* With respect to section 334.15(C) of the national  
9 electrical code, 2020 edition, all basement wiring from floor  
10 level to the underside of the floor joist must be installed  
11 in a conduit, either rigid or thin wall. Eighteen inches of  
12 nonmetallic cable in basements are permitted where receptacles  
13 are fed from basement junction boxes. Finished rooms in the  
14 basement may be wired in the type of wiring used throughout  
15 the house providing it is concealed before occupancy and final  
16 inspection. All exposed wires in garages and outbuildings  
17 shall be installed in conduit. Such conduit shall be parallel  
18 with walls and ceiling.

19 18. *Switches and circuit breakers.* With respect to section  
20 404.8(A) of the national electrical code, 2020 edition,  
21 switches and circuit breakers used as switches installed  
22 outdoors shall be installed no lower than thirty inches from  
23 the floor or finished grade, measured from the bottom of the  
24 panel, and include service panels and meter bases.

25 19. *Replacement of receptacles.* In lieu of the requirements  
26 of the first sentence of section 406.4(D)(4) of the national  
27 electrical code, 2020 edition, where a receptacle outlet  
28 is located in any areas specified in section 210.12(B) of  
29 the national electrical code, 2020 edition, a replacement  
30 receptacle at this outlet shall be one listed in section  
31 406.4(D)(4) of the national electrical code, 2020 edition.

32 20. *Receptacles in damp or wet locations.* In lieu of the  
33 requirements in the first sentence of section 406.9(C) of the  
34 national electrical code, 2020 edition, receptacles shall not  
35 be installed directly over a bathtub or shower.

1     21. *Optional standby systems.* With respect to the  
2 requirements of article 702 of the national electrical code,  
3 2020 edition, fixed and portable emergency standby generators  
4 shall not be installed or operated in front or side yards  
5 in residential districts or in other districts adjacent to a  
6 residential district. However, the building official may allow  
7 the use and installation of emergency standby generators in  
8 side yards when installation is not feasible in the required  
9 rear yard and the property owner takes reasonable steps to  
10 buffer the noise created by the unit through vegetation,  
11 enclosure of the generator, adding additional mufflers, or  
12 other means. The determination of acceptable buffering is at  
13 the sole discretion of the building official.

14     Sec. 3. Section 103.6, subsection 1, paragraph a, Code 2023,  
15 is amended by striking the paragraph.

16     Sec. 4. Section 103.6, subsection 2, Code 2023, is amended  
17 to read as follows:

18     2. The board may, in its discretion, revoke, suspend, or  
19 refuse to renew any license granted pursuant to [this chapter](#)  
20 when the licensee violates any provision of the national  
21 electrical code as ~~adopted pursuant to [subsection 1](#)~~, this  
22 chapter, or any rule adopted pursuant to [this chapter](#).

23     Sec. 5. Section 103.10, subsection 2, Code 2023, is amended  
24 to read as follows:

25     2. In addition, an applicant shall meet examination  
26 criteria based upon the ~~most recent~~ national electrical code  
27 ~~adopted pursuant to [section 103.6](#)~~ and upon electrical theory,  
28 as determined by the board.

29     Sec. 6. Section 103.12, subsection 2, Code 2023, is amended  
30 to read as follows:

31     2. In addition, an applicant shall meet examination  
32 criteria based upon the ~~most recent~~ national electrical code  
33 ~~adopted pursuant to [section 103.6](#)~~ and upon electrical theory,  
34 as determined by the board.

35     Sec. 7. Section 103.18, Code 2023, is amended to read as

1 follows:

2 **103.18 License renewal — continuing education.**

3 In order to renew a class A master electrician, class B  
4 master electrician, class A journeyman electrician, or class B  
5 journeyman electrician license issued pursuant to [this chapter](#),  
6 the licensee shall be required to complete eighteen contact  
7 hours of continuing education courses approved by the board  
8 during the three-year period for which a license is granted.  
9 The contact hours shall include a minimum of six contact hours  
10 studying the national electrical code ~~described in section~~  
11 ~~103.6~~, and the remaining contact hours may include study of  
12 electrical circuit theory, blueprint reading, transformer and  
13 motor theory, electrical circuits and devices, control systems,  
14 programmable controllers, and microcomputers or any other study  
15 of electrical-related material that is approved by the board.  
16 Any additional hours studying the national electrical code  
17 shall be acceptable. For purposes of [this section](#), “*contact*  
18 *hour*” means fifty minutes of classroom attendance at an approved  
19 course under a qualified instructor approved by the board.

20 Sec. 8. Section 103.26, Code 2023, is amended to read as  
21 follows:

22 **103.26 Condemnation — disconnection — opportunity to**  
23 **correct noncompliance.**

24 If the inspector finds that any installation or portion of  
25 an installation is not in compliance with accepted standards  
26 of construction for health safety and property safety, based  
27 upon minimum standards set forth in the local electrical code  
28 or the national electrical code ~~adopted by the board pursuant~~  
29 ~~to [section 103.6](#)~~, the inspector shall by written order condemn  
30 the installation or noncomplying portion or order service to  
31 such installation disconnected and shall send a copy of such  
32 order to the board, the state fire marshal, and the electrical  
33 utility supplying power involved. If the installation or the  
34 noncomplying portion is such as to seriously and proximately  
35 endanger human health or property, the order of the inspector

1 when approved by the inspector's supervisor shall require  
2 immediate condemnation and disconnection by the applicant. In  
3 all other cases, the order of the inspector shall establish a  
4 reasonable period of time for the installation to be brought  
5 into compliance with accepted standards of construction for  
6 health safety and property safety prior to the effective date  
7 established in such order for condemnation or disconnection.

8 Sec. 9. Section 103.29, subsection 5, Code 2023, is amended  
9 to read as follows:

10 5. A political subdivision that performs electrical  
11 inspections shall act as the authority having jurisdiction  
12 for electrical inspections and for amending the national  
13 electrical code ~~adopted by the board pursuant to section~~  
14 ~~103.6~~ for work performed within the jurisdictional limits of  
15 the political subdivision, provided those inspections and  
16 amendments conform to the requirements of **this chapter**. Any  
17 action by a political subdivision with respect to amendments  
18 to the national electrical code shall be filed with the board  
19 prior to enforcement by the political subdivision, and shall  
20 not be less stringent than the minimum standards established by  
21 the board by rule.

22 Sec. 10. Section 103.31, subsections 3 and 4, Code 2023, are  
23 amended to read as follows:

24 3. State inspection procedures and policies shall be  
25 established by the board. The state fire marshal, or the state  
26 fire marshal's designee, shall enforce the procedures and  
27 policies, and enforce the provisions of the national electrical  
28 code ~~adopted by the board~~.

29 4. Except when an inspection reveals that an installation or  
30 portion of an installation is not in compliance with accepted  
31 standards of construction for health safety and property  
32 safety, based upon minimum standards set forth in the local  
33 electrical code or the national electrical code ~~adopted by~~  
34 ~~the board pursuant to section 103.6~~, such that an order of  
35 condemnation or disconnection is warranted pursuant to section

1 103.26, an inspector shall not add to, modify, or amend a  
2 construction plan as originally approved by the state fire  
3 marshal or the state building code commissioner in the course  
4 of conducting an inspection.

5

EXPLANATION

6

The inclusion of this explanation does not constitute agreement with

7

the explanation's substance by the members of the general assembly.

8 This bill relates to the state electrical code. The bill  
9 adopts certain provisions of the national electrical code, 2020  
10 edition, with amendments, as the state electrical code. The  
11 bill strikes the ability of the national electrical examining  
12 board to adopt and amend a version of the national electrical  
13 code. The bill also makes conforming changes.